



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 11/23/2020  
Received: 11/20/2020  
Sampled By:  
Work Order: 0325009

**C** **Tooley Water District**  
**L** Attn: Matt Olson  
**I** PO Box 699  
**E** Newberg OR, 97132  
**N** Phone: (503) 537-4504  
**T**

**Project:** Tooley Water District  
Project # : N/A  
PWSID # : 4100911

Sampling Location:  
Sample Matrix: Drinking Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>0325009-01</b>	<b>Sample Name:</b> Nitrate - Well Lower Well						
	<b>Sampled:</b> 11/19/20 12:30						
<i>Inorganics</i>							
A Nitrate as N	1040	SM4500-NO3 D	mg/L	<b>22.5</b>	2.5	10	11/20/20 17:07 <b>MCLE</b>

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

*This report shall not be reproduced, except in full, without the written approval of the laboratory.*