



# Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 05/28/2021  
Received: 05/25/2021  
Sampled By:  
Work Order: 1145001

**C** **Tooley Water District**  
**L**  
**I** Attn: Matt Olson  
**E** PO Box 699  
**N** Newberg OR, 97132  
**T** Phone: (503) 537-4504

**Project:** Tooley Water District  
**Project # :** N/A  
**PWSID # :** 4100911

**Sampling Location:** Res.  
**Sample Matrix:** Drinking Water

### Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>1145001-01</b>	<b>Sample Name:</b> Nitrate <b>Sampled:</b> 5/24/21 17:40						
<i>Inorganics</i>							
A Nitrate as N	1040	SM4500-NO3 D	mg/L	2.1	0.5	10	05/25/21 17:10

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director